

-----Original Message-----

From: SAM LISTI [mailto:slisti@ci.belton.tx.us]

Sent: Wednesday, April 27, 2005 8:45 AM

To: Joe Trevino

Cc: LES HALLBAUER; FRED MORRIS

Subject: RE: Reply

Re. the water service to the homes in your subdivision.

I called Tony Beach, engineer with Beach and Clark, who made the following observations:

The city is prohibited from serving your area with water due to the existing CCN (Certificate of Convenience and Necessity) which limits service to Dog Ridge under state and federal regulations.

Even if Dog Ridge would consider releasing meters in this area, the city's current water distribution system could deliver no more than 30 psi of water pressure due to the elevation change in proximity to FM 1670. This is very marginal for residential needs.

Dog Ridge has completed design for a new elevated storage tank and has bought land on which to build it. It is my understanding from Mr. Beach, DRWSC engineer, that the tank should be up and operational within 12 months.

In summary, it appears that DRWSC will be your water provider for the indefinite future. SAL

-----Original Message-----

From: Joe Trevino [mailto:jtrevino@mclaneco.com]

Sent: Wednesday, April 27, 2005 8:27 AM

To: 'slisti@ci.belton.tx.us'

Subject:

Sam,  
Good morning!

you said you were going to give me an update about our water situation.

Joe